

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 6912-1615:102

Page 1 of 1

CATEGORY: Voice Communication Accessories

LISTEE: Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

DESIGN: Model EVX-4Z and EVX-2ZA zone splitters. These units are intended to be used in conjunction with a listee's separately listed Model EVAX25 audio adjunct system *(CSFM Listing No. 6911-1615:101). Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Input: 24-28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a voice communication/audio adjunct system accessories. Refer to listee's Installation Instruction Manual for details.

XL: **6912-1446:101**

*Corrected 06-15-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 28, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division